
CERTIFICATE OF APPROVAL

No CF 5500

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

ASSA ABLOY

Abloy Oy, Wahlforssinkatu 20, Fi-80101 Joensuu, Finland
Tel: 00 35840 5908486

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:


CERTIFIED PRODUCT

ASSA ABLOY DC340/DC340DA
ABLOY DC240/DC240DA
Surface Mounted Overhead
Door Closers

TECHNICAL SCHEDULE

TS 34 - The Contribution Of
Controlled Door Closing
Devices And Accessories To
Fire Resisting Doorsets

Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification



Sir Ken Knight
Chairman
Impartiality Committee



Paul Duggan
Certification Manager



Issued: 14th December 2016
Valid to: 13th December 2021

Page 1 of 4



CERTIFICATE No CF 5500

ASSA ABLOY

ASSA ABLOY DC340/DC340DA AND ABLOY DC240/DC240DA OVERHEAD DOOR CLOSERS

1. This applies to ASSA ABLOY DC340/DC340DA and ABLOY DC240/DC240DA rack and pinion overhead door closers with projecting arms only, but excludes any mechanical hold open variants.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), the Technical Handbooks (Scotland) and Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
3. This approval relates to its use with the following door assemblies: -

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (CERTIFIRE Code ITT).
4. The closer is approved on the basis of:
 - i) Initial type testing to EN1154 and BS EN 1634-1: 2000
 - ii) An appraisal against TS34
 - iii) Inspection of quality management system
 - iv) Inspection and surveillance of factory production control
 - v) Ongoing audit testing in accordance with EN 1154 requirements
5. This approval is applicable only to the specified closers when mounted in the applications stated later under the classification codes section of this certificate and used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
6. The approval relates to ongoing production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

CERTIFICATE No CF 5500 ASSA ABLOY

ASSA ABLOY DC340/DC340DA AND ABLOY DC240/DC240DA OVERHEAD DOOR CLOSERS

7. The following table show acceptable doorset types and fire resistance periods:

Class	Approved Door Type				
	IMM	MM	ITT	ITM	ITC
FD20	x	x	✓	x	x
FD30	x	x	✓	x	x
FD60	x	x	✓	x	x
FD90	x	x	✓	x	x
FD120	x	x	✓	x	x
FD240	x	x	x	x	x
E 20	x	x	✓	x	x
EI 20	x	x	✓	x	x
E 30	x	x	✓	x	x
EI 30	x	x	✓	x	x
E 60	x	x	✓	x	x
EI 60	x	x	✓	x	x
E 90	x	x	✓	x	x
EI 90	x	x	✓	x	x
E 120	x	x	✓	x	x
EI 120	x	x	✓	x	x
E 240	x	x	x	x	x
EI 240	x	x	x	x	x

Key:

- ✓ - approved
- x - Not approved

CERTIFICATE No CF 5500

ASSA ABLOY

ASSA ABLOY DC340/DC340DA AND ABLOY DC240/DC240DA OVERHEAD DOOR CLOSERS

8. Doors are classified as the following types:

Type MM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that do not contain intumescent materials in the frame to leaf gap.

Type IMM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

Type ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

Type ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

Type ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Scope of Approval:

- All applications apply to unglazed doorsets and glazed doorsets incorporating an uninsulated glass panel size of less than 20% of the leaf area.
- The closer application is as referenced in the Classification code section below in accordance with EN 1154.

Classification codes:

Figure 1 and Figure 61 - projecting arm applications.

4	8	6 3	1	1	3
---	---	--------	---	---	---

Further Information

Further information regarding the details contained in this certificate may be obtained from Abloy Oy (Tel: 00 35840 5908486).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).