

### Hardware performance sheet (HPS) – Abloy Scan Motor Hookbolt range

**Sponsor:** Abloy Oy  
Wahlforssinkatu 20  
PL108  
FI-80100 Joensuu  
FINLAND

**Prepared by:** Eurofins Expert Services Oy  
Fire Safety  
Kivimiehentie 4, FI-02150 Espoo  
FINLAND

**Notified Body No:** 0809\*

**Product name:** Scan Motor Hookbolt range

**Report number** EUFI29-25003604-T1

**Issue Number:** 1

**Date of issue:** October 28, 2025

This HPS consists of four pages and one appendix and may only be used or reproduced in its entirety.

\* To be used for CE marking only.

**1****Introduction**

Hardware performance sheet process is carried in conformity with EN 16035:2023 "Hardware performance sheet (HPS) – Identification and summary of test evidence to facilitate the interchangeability of building hardware for application to fire resisting and/or smoke control doorsets and/or openable windows".

This document concerns test results obtained in accordance with Test Method EN 1634-1:2014+A1:2018 "Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware - Part 1: Fire resistance test for door and shutter assemblies and openable windows".

**2.****HPS****2.1****General**

Product is Solid door security lock with latch and hookbolt.

The element hinged single leaf steel door is defined as a fire resisting steel door.

**2.2****Building hardware identification**

Table 1 Building hardware

Line	Feature	Required indication / properties	Additional information
1.1	<b>HPS No. / version</b>	EUFI29-25003604-T1	
1.2	<b>Date</b>	October 28, 2025	
1.3	<b>Prepared by</b>	Eurofins Expert Services Oy	
1.4	<b>Manufacturer</b>	Abloy Oy Wahlforssinkatu 20 PL108 FI-80100 Joensuu FINLAND	
1.5	<b>Type of building hardware</b>	Security lock with latch and hookbolt	
1.6	<b>Product line</b>	EL558 EL572, EL574, EL874	Suitable strike plate EA342, EA343
1.7	<b>Relevant EN standard or EAD</b>	EN 14846:2008	
1.8	<b>Classification / performance</b>	Grade B, C, D, E, F	Suitable for use on fire door assemblies
1.9	<b>Test evidence used</b>	1	EUFI29-25000162-T2, dated June 11, 2025



This report may be published in its entity, parts of it only with a written permission by Eurofins

Table 2 Test evidence used

Line	Feature	Required indication / properties	Additional information
2.1	<b>HPS No.</b>	EUFI29-25003604-T1	
2.2	<b>No. of test evidence</b>	1	EUFI29-25000162-T2, dated June 11, 2025
2.3	<b>Product version</b>	Lock case EL558	EL558 includes most of the flammable material and was chosen to represent the product line; Strike plate EA342
2.4	<b>Main dimensions of the specific building hardware</b>	Forend: 22 mm x 225 mm x 4 mm Lock case: 74 mm x 167.5 mm x 20 mm	
2.5	<b>Fixing, building hardware to element</b>	Lock case two screws	Strike plate four screws
2.6	<b>Settings</b>	During nighttime the hookbolt is locked and the door is kept closed with latch and hookbolt. During the daytime the hookbolt is open and the latch bolt keeps the door closed.	
2.7	<b>Type of doorset or openable window</b>	Single leaf steel doorset	
2.8	<b>Type of material of the element frame</b>	Steel, RT-frame	
2.9	<b>Element frame thickness</b>	s=1.75 mm Fe/Zn	
2.10	<b>Mode of operation</b>	Hinged	
2.11	<b>Mounting position building hardware</b>	Mortice mounted, fire on both sides	
2.12	<b>Building hardware is mounted on</b>	Primary door leaf	
2.13	<b>Leaf mass</b>	148 kg	
2.14	<b>Leaf width</b>	1020 mm	
2.15	<b>Leaf height</b>	2120 mm	
2.16	<b>Leaf thickness</b>	95 mm	
2.17	<b>Thermal separation</b>	-	
2.18	<b>Insulation layer</b>	Mg-board + 2x rockwool layer + Mg-board	
2.19	<b>Intumescent layer</b>	-	
2.20	<b>Seals or gaskets</b>	2x Marvon 2 mm x 45 mm	



Table 3 Performance level(s) fire resistance

Line	Feature	Required indication / properties	Additional information
3.1	<b>Related HPS No. and test evidence used</b>	EUFI29-25003604-T1	
3.2	<b>Fire resistance test</b>	EN 1634-1	
3.3	<b>No. test report</b>	1	EUFI29-25000162-T2, dated June 11, 2025
3.4	<b>Notified test body</b>	0809	
3.5	<b>Direction of test exposure</b>	Towards the fire and away from the fire	
3.6	<b>Precondition test</b>	25	
3.7	<b>Classification</b>	EN 13501-2: E 120 + overrun EI <sub>1</sub> 60 + overrun EI <sub>2</sub> 120 + overrun	EUFI29-25000162-T2: the fire resistance test was terminated 150 min 20 s
3.8	<b>Observations during the test related to hardware</b>	-	
3.9	<b>Applicable EXAP Standard</b>	EN 15269-2	
3.10	<b>Data confirmed by</b>	Issued by Eurofins Expert Services Oy	

### 3

#### Limitations

The HPS together with mentioned test reports in Table 2 shall be a part of the technical documentation delivered to Notified Body for an Extended application report, prior to CE-marking.

This document does not represent type approval or certification of the product.

Eurofins Expert Services Oy is notified body No. 0809 under the Construction Products Regulation (CPR).

Espoo, October 28, 2025

SIGNED

APPROVED

Matias Huusko  
Senior Expert

Teemu Vesala  
Senior Expert

Appendices

Appendix 1 Material parts EL558 EL572 EL574 EL874 and EA342 EA343

Distribution

Customer electronically approved  
Eurofins Expert Services Oy/ Archive electronically approved



This report may be published in its entity, parts of it only with a written permission by Eurofins