

EN 16035 :2023 Hardware performance sheet

EL596FU

No : HPS240001-00

Table 1 Building hardware

| Line | Feature | Required indication / Properties | | | | | | | | | | | | | | | | | | |
|------|------------------------------|--|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1.1 | HPS No./version | HPS240001-00 | | | | | | | | | | | | | | | | | | |
| 1.2 | Date | 13.8.2024 | | | | | | | | | | | | | | | | | | |
| 1.3 | Prepared by | Abloy Oy, Testing, Maarit Jumppanen. | | | | | | | | | | | | | | | | | | |
| 1.4 | Manufacturer | Abloy Oy | | | | | | | | | | | | | | | | | | |
| 1.5 | Type of building hardware | Electric lock | | | | | | | | | | | | | | | | | | |
| 1.6 | Product line | EL596 | | | | | | | | | | | | | | | | | | |
| 1.7 | Relevant EN standard | EN 14846: 2008 | | | | | | | | | | | | | | | | | | |
| 1.8 | Classification / performance | <table><tr><td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td><td>9</td></tr><tr><td>3</td><td>S</td><td>5</td><td>F</td><td>-</td><td>L</td><td>3</td><td>1</td><td>1</td></tr></table> <p>Category of use/Durability and load on latchbolt/Door mass and closing force/ Suitability for use on fire /Smoke doors/Safety/Corrosion resistance, temperature and humidity/Security/Security - electrical function/Security - electrical manipulation</p> | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 3 | S | 5 | F | - | L | 3 | 1 | 1 |
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | | | | | | | | | | | | |
| 3 | S | 5 | F | - | L | 3 | 1 | 1 | | | | | | | | | | | | |
| 1.9 | Test evidence used | VTT-S-00636-14, VTT-S-00746-18 | | | | | | | | | | | | | | | | | | |

Table 2 Test evidence used

| Line | Feature | Required indication / Properties |
|------|---|---|
| 2.1 | HPS No./version | HPS240001-00 |
| 2.2 | No. of test evidence | EXAP – EUFI29-19005329-T2 |
| 2.3 | Product version | EL596FU |
| 2.4 | Main dimensions of the specific building hardware | <p>Dimensions (height x width x depth): lock body 159 mm x 20.5 mm x 79 mm forend 225.5 mm x 22 mm x 3 mm</p> <p>(Technical drawings with dimensions attached).</p> <p>EL596FU represents the whole product family as it has biggest fire load, with largest main dimensions and largest cutout on fire door. EL596FL and EL596 are equal size, fire load is equal (EL596FL) / smaller (EL596)</p> <p>EL581, EL583, BL581, BL583 are smaller sizes. Dimensions: lock body 158 mm x 20 mm x 79 mm forend 225.5 mm x 21.8 mm x 3 mm</p> <p>LC102, LC190, LC193, LC194, LC197, LC290, LC291 are smaller sizes. Dimensions: lock body 152 mm x 19 mm x 77 mm forend 225 mm x 22 mm x 4 mm</p> <p>OP193, LE180, LE184 are smaller sizes. Dimensions:</p> |

| | | |
|------|--|---|
| | | lock body 152 mm x 19 mm x 78mm forend 225 mm x 22 mm x 4 mm |
| 2.5 | Fixing, building hardware to element | - |
| 2.6 | Settings | - |
| 2.7 | Material of doorset and/or openable window | <input checked="" type="checkbox"/> Steel doorset <input type="checkbox"/> Aluminum doorset <input type="checkbox"/> Metal framed glazed doorset <input type="checkbox"/> Timber <input type="checkbox"/> Additional information |
| 2.8 | Type and material of the element frame | Type - Material <input checked="" type="checkbox"/> Steel <input type="checkbox"/> Aluminum <input type="checkbox"/> Timber |
| 2.9 | Element frame thickness | 118 mm |
| 2.10 | Mode of operation | <input checked="" type="checkbox"/> Hinged <input type="checkbox"/> Pivoted <input type="checkbox"/> Sliding <input checked="" type="checkbox"/> Single leaf <input type="checkbox"/> Double leaf |
| 2.11 | Mounting position building hardware | <input type="checkbox"/> Surface mounted <input checked="" type="checkbox"/> Mortise mounted |
| 2.12 | Building hardware is mounted on | <input checked="" type="checkbox"/> Primary (single /active) leaf <input type="checkbox"/> Secondary (inactive) leaf |
| 2.13 | Leaf mass | 141 kg (including frames) |
| 2.14 | Leaf width | 904 mm |
| 2.15 | Leaf height | 2001 mm |
| 2.16 | Leaf thickness | 114 mm |
| 2.17 | Thermal separation | - |
| 2.18 | Insulation layer | Stone wool slabs, Glasrock plaster boards |
| 2.19 | Intumescent layer | - |
| 2.20 | Seals or gaskets | <input checked="" type="checkbox"/> Yes. Around the door leaf (except bottom side of the door leaves) and around the inner side of the door frame there were parallel 30 mm x 2 mm intumescent seals. In both vertical frame parts there were 20 mm x 2 mm intumescent seals. <input type="checkbox"/> N/A |

Table 3 Performance level(s) fire resistance

| Line | Feature | Required indication / Properties |
|------|--------------------------------|---|
| 3.1 | HPS No. and test evidence used | HPS240001-00 EUFI29-19002003-T1 |
| 3.2 | Fire resistance test | <input checked="" type="checkbox"/> EN 1634-1 :2014 + A1:2018 <input type="checkbox"/> EN 1634-2:2008 |
| 3.3 | No. Test report | EUFI29-19002003-T1 |
| 3.4 | Notified test body | 0809 Eurofins Expert Services Oy |
| 3.5 | Direction of test exposure | <input checked="" type="checkbox"/> Towards the furnace <input checked="" type="checkbox"/> Away the furnace |
| 3.6 | Precondition test | <input checked="" type="checkbox"/> 25 cycles <input type="checkbox"/> 5000 cycles <input type="checkbox"/> N/A |
| 3.7 | Classification | <input checked="" type="checkbox"/> EN 13501-2 classification including overrun time |

| | | | | |
|------|--|---|------------|---|
| | | E: 149 min W: 149 min I ₁ : 90 min I ₂ : 149 min <input type="checkbox"/> N/A | | |
| 3.8 | Observations during the test related to hardware | Time (min:s) | E/U | Observation E = exposed side, U = unexposed |
| | | 0:00 | | Test was started. |
| | | 1:00 | U | Heavy smoking started from both door |
| | | 32:50 | U | Door B: the surface of the door was buckling |
| | | 51:00 | U | Door B: tc36 had detached from the frame. |
| | | 112:30 ...113:00 | U | Door B: Cotton wool pad test was performed on the gap between door leaf and frame next to the lock. Neither burning nor glowing. |
| | | 116:00 | U | Door A: rowing thermocouple was used at the place of detached tc36. Measured temperature was 182° C. |
| | | 145:15 ...145:45 | | Door A: Cotton wool pad test was performed on the gap between door leaf and frame next to tc9 and tc14. Neither burning nor glowing |
| | | 149:10 | U | Test was terminated. |
| | | Door A opened towards fire, Door B opened away fire | | |
| 3.9 | Applicable EXAP Standard | <input checked="" type="checkbox"/> EN 15269-2 Part 2 Fire resistance of hinged and pivoted steel doorsets <input type="checkbox"/> EN 15269_3 Part 3 Fire resistance of hinged and pivoted timber doorsets <input type="checkbox"/> EN15269-5 2014 A1:2016 Part 5 Hinged and pivoted metal framed glazed doorsets and openable windows <input type="checkbox"/> N/A | | |
| 3.10 | Data confirmed by | Not confirmed by Notified body | | |

Joensuu 2024-08-15

Signed for and on behalf of Abloy Oy




Minna Sallinen
VP Digital Access Solutions BU

Joensuu 2024-08-15

Signed for and on behalf of Abloy Oy





Jari Kervinen
Director and Head of Innovation, Mechanical Core PU Nordic




EL596, EL596FU, EL596FL

ABLOY® EL581,-3







900496-A
LC190




900504-A
LC193







900499-A
LC197




900500-A
LC290



900501-A
LC291



900456
LE180,LE185



900457
LE184